

La Collette Energy from Waste Facility Performance Table

Emissions						
2012	Hydrogen Chloride	Sulphur Dioxide	Nitrous Oxide	Carbon Monoxide	Particulates	Volatile Organic Compound
Month	Expressed as a percentage of the maximum 30 minute limit.					
January	10.40%	5.80%	39.80%	7.60%	0.80%	3.90%
February	12.40%	13.40%	39.20%	9.20%	0.70%	3.30%
March	12.20%	9.50%	36.90%	9.00%	0.80%	3.30%
April	8.10%	9.50%	38.70%	5.60%	3.60%	0.30%
May	9.50%	7.70%	34.40%	33.90%	0.90%	7.40%
June	12.60%	9.40%	40.80%	6.50%	0.80%	4.60%
July	12.70%	8.60%	42.20%	5.30%	1.00%	4.50%
August	14.20%	7.10%	47.60%	5.60%	0.80%	4.80%
September	7.00%	3.40%	23.70%	7.70%	0.30%	2.20%
October	14.20%	8.70%	46.90%	23.20%	3.20%	5.10%
November	12.90%	7.40%	46.00%	10.40%	0.90%	0.30%
December	14.30%	9.60%	45.30%	8.60%	0.80%	7.10%