

La Collette Energy from Waste Facility Performance Table

Emissions						
2017	Hydrogen Chloride	Sulphur Dioxide	Nitrous Oxide	Carbon Monoxide	Particulates	Volatile Organic Compound
Month	Expressed as a percentage of the maximum 30 minute limit.					
January	13.73%	14.69%	45.99%	12.27%	0.87%	3.03%
February	13.42%	12.99%	42.22%	9.54%	0.86%	5.14%
March	15.20%	15.38%	43.52%	13.66%	0.92%	6.72%
April	12.83%	10.65%	44.54%	7.88%	1.00%	5.33%
May	13.37%	11.11%	46.31%	8.24%	1.04%	5.44%
June	14.21%	8.27%	46.79%	9.24%	1.16%	4.83%
July	14.36%	8.71%	45.37%	9.65%	1.28%	5.33%
August	14.21%	8.00%	46.44%	7.48%	1.21%	5.97%
September	13.90%	6.14%	46.26%	8.14%	1.14%	6.73%
October	13.91%	6.15%	45.99%	10.07%	1.10%	8.09%
November	13.93%	5.03%	46.18%	9.04%	1.10%	11.45%
December	13.09%	9.39%	45.72%	9.81%	1.32%	10.45%