

Date of Call	Time of Call	Address	Post Code	Dwelling Type	Supposed Cause	Most Likely Cause	Place Where Fire Started (1)	Damage	Damage Area
17 Apr 2015	12:54:55	FORT REGENT LEISURE CENTRE, FORT REGENT, ST HELIER, JERSEY, JE2 4UX	JE2 4UX	Non Residential: Entertainment - Other entertainment venue		Accidental -	Dwelling - Kitchen	Buildings - Limited to item 1st ignited	None
08 May 2015	22:20:05			Non Residential: Retail - Large supermarket	Capacitor within a UPS system over heated and caused the ring main to trip. Computer protec summon and removed damaged item from office. The house keeping of the general area was untidy and the manager was informed of this by SM Russell	Accidental -	Non Residential - Office	Buildings - Limited to item 1st ignited	None
07 Jun 2015	17:01:51	PUBLIC TOILETS, LA ROUTE DE LA HAULE, ST BRELADE, JERSEY, JE3 8BA	JE3 8BA	Non Residential: Public toilets	There was clear evidence of arson as there were two fires in compartments with no ignition sources.	Deliberate - others Property	Non Residential - Bathroom/Toilet	Buildings - Limited to room of origin	Up to 5 square metres
23 Jun 2015	19:03:44	ASHBURTON (JERSEY) LTD 17, HILARY STREET, ST HELIER, JERSEY, JE2 4SX	JE2 4SX	Non Residential: Office - Purpose built		Accidental -	Non Residential - Meeting room		Up to 5 square metres
13 Aug 2015	14:55:03	SUTTON HOUSE 28-30, THE PARADE, ST HELIER, JERSEY, JE2 3QQ	JE2 3QQ	Non Residential: Office - Purpose built	Burnt electrical cable in Heating & Ventilation motor room. Smoke issued into building by ventilation ducts.	Accidental -	Non Residential - Power house/Plant/Generator	Buildings - Limited to item 1st ignited	None
20 Aug 2015	09:55:06	KFC, LA RUE DE LETAU, ST HELIER, JERSEY, JE2 3WF	JE2 3WF	Non Residential: Food and Drink - Takeaway fast food	Burnt out motor in air conditioning unit	Accidental -	Non Residential - Other	Buildings - Limited to item 1st ignited	None
27 Nov 2015	21:16:34	CONTAINER SHED NEXT TO, EAST BERTH ELIZABETH TERMINAL, LA ROUTE DU PORT ELIZABETH, ST HELIER, JERSEY, JE2 3NW	JE2 3NW	Non Residential: Warehouses and bulk storage - Other	Fuel leaking onto hot parts of engine motor (exhaust/turbo)	Accidental -	Non Residential - Power house/Plant/Generator	Buildings - Limited to item 1st ignited	None
01 Dec 2015	07:09:25			Non Residential: Hospitals and medical care - Medical/health centre	Small fire in two bulb fluorescent light fitting. Electricity supply isolated, bulbs and cover removed to reveal overheated and charred wiring and unidentified component (possibly capacitor).	Accidental -	Non Residential - Office	Buildings - Limited to item 1st ignited	Up to 5 square metres
07 Dec 2015	04:57:07	GALLICHAN MARINE LTD, LE BOULEVARD, ST BRELADE, JERSEY, JE3 8AB	JE3 8AB	Non Residential: Retail - Other retail	The most likely cause was a deliberate act. A number of fuel cans were found inside the property and traces of an accelerant were found inside what was a small office and other locations in the general shop area.	Deliberate - own Property	Non Residential - Shop floor/Showroom/Display hall	Buildings - Whole building	201 – 500 square metres
22 Dec 2015	09:58:17	JERSEY TELECOMS SHOP, MINDEN PLACE, ST HELIER, JERSEY, JE2 4WQ	JE2 4WQ	Non Residential: Public Utilities - Telephone exchange		Not known	Non Residential - Power house/Plant/Generator	Buildings - Limited to item 1st ignited	Up to 5 square metres
25 Jan 2016	08:46:50	LE BRAYE CAFE, LA GRANDE ROUTE DES MIELLES, ST BRELADE, JERSEY, JE3 8FN	JE3 8FN	Non Residential: Food and Drink - Other Restaurant/café – (not licensed for the sale of alcohol)	Possibility that an object had fallen into hot oil and caused ignition.	Accidental -	Non Residential - Kitchen	Buildings - Limited to item 1st ignited	None
08 Feb 2016	19:16:36	FCJ PRIMARY SCHOOL, ST SAVIOURS HILL, ST SAVIOUR, JE2 7XB	JE2 7XB	Non Residential: Education - Infant/Primary school	Burnt plastic.	Accidental -	Non Residential - Kitchen	Buildings - Limited to item 1st ignited	None
25 Feb 2016	20:37:20	VIBERT & BRIDLE LTD 41, HILL STREET, ST HELIER, JERSEY, JE2 4UA	JE2 4UA	Non Residential: Offices - Converted office	Fault with electrical transformer supplying fluorescent light tube in external illuminated business sign	Accidental -	Non Residential - External fittings	Buildings - Limited to item 1st ignited	Up to 5 square metres
16 Mar 2016	17:31:45	FEAST, GOREY PIERHEAD, GOREY PIER, ST MARTIN, JERSEY, JE3 6EW	JE3 6EW	Non Residential: Food and Drink - Other Restaurant/café – (licensed for sale of alcohol)	Grease behind griddle pan caught alight	Accidental -	Non Residential - Canteen/Restaurant	Buildings - Limited to item 1st ignited	Up to 5 square metres
18 Mar 2016	17:02:49	THE GREEN OLIVE, ANLEY STREET, ST HELIER, JERSEY, JE2 3QE	JE2 3QE	Non Residential: Food and Drink - Other Restaurant/café – (licensed for sale of alcohol)		Accidental -	Non Residential - Kitchen	Buildings - Limited to room of origin	6 to 10 square metres
07 Apr 2016	18:47:39	LE MARAIS ESTATE, LE MARAIS, ST CLEMENT, JERSEY,		Non Residential: Public Utilities - Water works	Area of less than one square metre of glass reinforced plastic flat roof damaged by fire, most likely started deliberately by youths (eye witness statements and information given by States Police). Evidence at scene of three empty boxes of barbecue fire lighters, along with broken-up fire lighters	Deliberate - others Property	Non Residential - Roof	Buildings - External roof only	Up to 5 square metres
08 Apr 2016	04:58:12	(PUBLIC TOILE), CONWAY STREET, ST HELIER, JERSEY, JE2 3NT	JE2 3NT	Non Residential: Public toilets	Deliberate cause to attract attention due to an attack of paranoia.	Deliberate - others Property	Non Residential - Bathroom/Toilet	Buildings - Limited to item 1st ignited	None
23 Apr 2016	11:34:07	ROMERILS, DUMARESQ STREET, ST HELIER, JERSEY, JE2 3RL	JE2 3RL	Non Residential: Retail - Department Store	Possible water leak onto electrical connections.	Accidental -	Non Residential - Other	Buildings - Limited to item 1st ignited	Up to 5 square metres
06 Jun 2016	16:22:29	CHECKERS EXPRESS, QUEENS RD A9, ST HELIER, JE2 3GR	JE2 3GR	Non Residential: Retail - Single shop	Fault on refrigeration unit.	Accidental -	Non Residential - Shop floor/Showroom/Display hall		
27 Jul 2016	16:29:17	ENERGY FROM WASTE PLANT LA COLLETTE PHASE II SITE, LA ROUTE DU VEULE, ST HELIER, JERSEY,		Non Residential: Public Utilities - Electricity power station	Unknown ignition source but possibly flares being disposed through domestic waste.	Accidental -	Non Residential - Process/Production room	Buildings - Limited to room of origin	6 to 10 square metres
05 Aug 2016	15:17:16	BREAKWATER CAFE, LA ROUTE DE ST CATHERINE, ST MARTIN, JERSEY, JE3 6DD	JE3 6DD	Non Residential: Food and Drink - Other Restaurant/café – (not licensed for the sale of alcohol)	Ignition of cooking residue in ducting.	Accidental -	Non Residential - External fittings	Buildings - Limited to item 1st ignited	Up to 5 square metres
12 Aug 2016	02:10:02	COSTCUTTER, LA GRANDE ROUTE DE LA COTE, ST CLEMENT, JERSEY, JE2 6FF	JE2 6FF	Non Residential: Retail - Single shop		Accidental -	Non Residential - Shop floor/Showroom/Display hall		
11 Sep 2016	07:13:23	ENERGY FROM WASTE PLANT LA COLLETTE PHASE II SITE, LA ROUTE DU VEULE, ST HELIER, JERSEY,		Non Residential: Warehouses and bulk storage - Waste	Most likely cause item in waste capable of causing ignition (e.g. distress flare)	Accidental -	Non Residential - Refuse store	Buildings - Limited to floor of origin (not whole building)	21 to 50 square metres
21 Sep 2016	13:47:47	FALLES ACCIDENT REPAIR CENTRE, LA ROUTE DES QUENNEVAIS, ST BRELADE, JERSEY, JE3 8FP	JE3 8FP	Non Residential: Vehicle Repair	Flue from spray booth had become dislodged causing burning to roof joist.	Accidental -	Non Residential - Chimney	Buildings - Limited to item 1st ignited	Up to 5 square metres

24 Dec 2016	20:31:23	RAYNER WARD, GENERAL HOSPITAL, GLOUCESTER STREET, ST HELIER, JERSEY, JE2 3QR	JE2 3QR	Non Residential: Hospitals and medical care -Hospital	Smell of burning traced to the battery pack of mobile computer equipment. The battery showed 40 degrees celsius with thermal camera (identical equipment in use showed as ambient temperature). Battery pack removed and leaked small amount of unidentified liquid, possibly battery electrolyte.	Accidental -	Non Residential - Corridor/Hall	Buildings - Limited to item 1st ignited	Up to 5 square metres
-------------	----------	--	---------	---	--	--------------	---------------------------------	---	-----------------------