

From: [Andrew Scate](#)
To: [Kevin Lewis](#); [REDACTED]
Subject: FW: LQS air handling
Date: 17 September 2021 11:56:19
Attachments: [image001.png](#)
[Les Quennevais School - Classroom ventilation \(5.39 MB\).msg](#)

From: Tim Daniels <T.Daniels@gov.je>
Sent: 17 September 2021 11:14
To: Andrew Scate <A.Scate@gov.je>
Cc: [REDACTED] <[REDACTED]@gov.je>
Subject: RE: LQS air handling

The school does not have mechanical cooling, in common with the other schools, however, in order to sustain the environmental characteristics, it does not have opening windows which is the cause of some consternation with the Head. It was opened last September where there were a couple of hot days, as this year, however the school continues to operate within the design parameters of BB101 as explained in the attachment. Notwithstanding, we are investigating mechanical cooling for the problem areas, there will however be a cost attached to that which will have implications elsewhere in the portfolio. We continue to monitor temperatures and believe that we realistically have a period of time until spring next year to design, price, procure and install any additional cooling systems.

Tim Daniels

From: Andrew Scate <A.Scate@gov.je>
Sent: 17 September 2021 10:58
To: [REDACTED] <[REDACTED]@gov.je>; Tim Daniels <T.Daniels@gov.je>
Subject: LQS air handling

Hi both

Can I have an update on this please, as it seems to have been an issue since the building was commissioned?

Thanks
Andy

Andy Scate
Director General
Infrastructure Housing and Environment

Direct: [REDACTED]

Government of Jersey
PO Box 412 | Maritime House | St Helier | Jersey | JE4 8UY



Customer focus - Constantly improving - Better together - Always respectful - We deliver