

La Collette Energy from Waste Facility Performance Table

Emissions						
2013	Hydrogen Chloride	Sulphur Dioxide	Nitrous Oxide	Carbon Monoxide	Particulates	Volatile Organic Compound
Month	Expressed as a percentage of the maximum 30 minute limit.					
January	14.80%	12.30%	47.00%	9.10%	0.80%	4.00%
February	15.30%	52.20%	24.50%	0.30%	2.20%	2.80%
March	13.80%	9.70%	43.60%	6.90%	1.20%	2.50%
April	14.60%	12.20%	45.80%	4.70%	1.20%	3.40%
May	14.60%	9.80%	44.90%	5.60%	0.90%	3.50%
June	15.40%	10.30%	43.00%	7.20%	1.70%	0.90%
July	18.30%	9.40%	46.00%	4.30%	0.80%	0.30%
August	13.30%	7.30%	44.90%	7.50%	0.80%	1.00%
September	12.70%	6.10%	45.70%	10.40%	2.20%	2.80%
October	12.20%	8.00%	46.20%	10.80%	15.90%	2.20%
November	10.50%	14.20%	46.30%	18.20%	4.80%	5.30%
December	14.20%	6.40%	46.00%	7.10%	0.90%	2.90%