

## La Collette Energy Recovery Facility Performance Table

	Emissions					
2018	Hydrogen Chloride	Sulphur Dioxide	Nitrous Oxide	Carbon Monoxide	Particulates	Volatile Organic Compound
Month	Expressed as a percentage of the maximum 30 minute limit.					
January	13.36%	7.25%	46.13%	9.76%	1.35%	7.90%
February	14.28%	7.82%	46.37%	9.12%	2.42%	5.79%
March	14.33%	7.45%	46.48%	8.96%	2.84%	7.82%
April	14.26%	7.93%	46.90%	9.56%	2.17%	6.78%
May	13.90%	7.23%	46.02%	8.88%	2.21%	2.19%
June	14.27%	5.15%	46.50%	9.17%	2.06%	4.68%
July	13.72%	6.18%	46.88%	7.19%	1.65%	6.31%
August	13.95%	6.57%	45.06%	7.17%	2.34%	6.50%
September	14.07%	5.56%	46.52%	7.73%	2.38%	4.67%
October	14.26%	8.06%	46.56%	8.82%	2.44%	2.20%
November	13.58%	6.60%	45.09%	7.20%	2.33%	0.34%
December	13.73%	8.72%	46.56%	7.75%	1.37%	2.71%