

La Collette Energy Recovery Facility Performance Table

	Emissions					
2019	Hydrogen Chloride	Sulphur Dioxide	Nitrous Oxide	Carbon Monoxide	Particulates	Volatile Organic Compound
Month	Expressed as a percentage of the maximum 30 minute limit.					
January	14.37%	9.21%	46.83%	7.36%	1.88%	9.12%
February	13.80%	8.95%	46.31%	6.65%	1.91%	0.03%
March	14.70%	5.27%	46.82%	8.75%	2.26%	2.19%
April	14.20%	3.15%	46.70%	12.77%	0.84%	3.21%
May	14.35%	5.06%	46.70%	9.14%	5.27%	7.35%
June	15.18%	5.51%	46.54%	9.72%	5.90%	12.01%
July	14.48%	6.26%	44.94%	6.31%	7.55%	13.58%
August	14.80%	6.51%	45.46%	6.60%	2.14%	9.00%
September	14.56%	6.25%	46.35%	7.93%	1.37%	6.88%
October	14.19%	7.53%	46.74%	8.08%	0.98%	2.24%
November	13.45%	6.40%	43.77%	10.45%	1.07%	1.70%
December	13.77%	6.15%	45.51%	7.25%	1.04%	6.72%