

La Collette Energy Recovery Facility Performance Table

	Emissions					
2021	Hydrogen Chloride	Sulphur Dioxide	Nitrous Oxide	Carbon Monoxide	Particulates	Volatile Organic Compound
Month	Expressed as a percentage of the maximum 30 minute limit.					
January	13.89%	5.74%	45.60%	7.04%	1.06%	6.03%
February	14.87%	6.17%	44.62%	7.79%	1.06%	5.39%
March	7.17%	6.49%	39.02%	4.92%	0.40%	4.92%
April	14.43%	11.05%	41.18%	6.07%	1.05%	5.18%
May	15.02%	9.80%	38.89%	5.43%	1.10%	4.22%
June	7.54%	3.52%	20.37%	4.16%	0.65%	3.41%
July	12.91%	7.07%	41.58%	5.88%	0.98%	3.13%
August	14.05%	7.21%	39.96%	7.88%	1.04%	4.27%
September	14.55%	9.60%	43.64%	7.93%	1.13%	5.72%
October	14.60%	10.81%	44.11%	10.45%	1.08%	3.38%
November	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%
December	12.76%	12.55%	45.24%	10.21%	0.39%	1.02%