Week 13

The Department of the Environment collects seawater samples on a weekly basis during the bathing water season. This is to measure bacterial levels in line with the 2006 Bathing Water Directive.

Bathing Water	Sampling date	Escherichia coli cfu/100ml	Intestinal enterococci cfu/100ml	Quality
Greve de Lecq	08 August 2018	<10	6	***
Bouley Bay	08 August 2018	20	11	***
Archirondel	08 August 2018	<10	<3	***
Grouville Bay	08 August 2018	80	37	***
Green Island	08 August 2018	10	6	***
Havre des Pas	08 August 2018	<10	<3	***
Victoria Pool	08 August 2018	30	29	***
La Haule	08 August 2018	<10	17	***
Portelet	08 August 2018	<10	<3	***
St Brelade's Bay	08 August 2018	60	29	***

cfu (colony forming units)

< (is less than the given value)

The above ratings are a weekly snapshot of bathing water quality, however, the full classification is calculated annually for each bathing water site, based on all of the samples from the previous four years.



Excellent Water Quality: Indicates this sample meets the following standard: less than or equal to 250 *Escherichia coli* per 100ml; less than or equal to 100 Intestinal enterococci per 100ml



Good Water Quality: Indicates this sample meets the following standard: less than or equal to 500 *Escherichia coli* per 100ml; less than or equal to 200 Intestinal enterococci per 100ml



Poor Water Quality: Values are above 500 *Escherichia coli* per 100ml and above 200 Intestinal enterococci per 100ml

The bathing water profiles can be found at www.gov.je/seawater