

TOILET REQUIREMENTS FOR LICENSED PREMISES AND PLACES OF REFRESHMENT

Applies to new or substantially altered premises after 1st March 1995

PUBLIC HOUSES Categories 1,4,5,7					
Maximum Number of Patrons	Minimum Requirements				
	For Female Patrons		For Male Patrons		
	WCs	Washbasins	WCs	Urinals	Washbasins
1 to 25	1	1	1	0	1
26 to 50	2	1	1	2	2
51 to 100	3	2	1	2	2
101 to 150	4	2	1	3	2
151 to 200	5	3	1	3	2
201 to 250	6	3	2	3	3
251 to 300	7	4	2	4	3
301 to 350	8	4	2	5	3
351 to 400	9	5	2	6	4
401 to 450	10	5	3	6	5
451 to 500	11	6	3	7	5
501 to 550	12	6	3	7	5
551 to 600	13	7	3	8	5
601 to 650	14	7	3	9	5
651 to 700	15	8	4	9	6

LICENSED RESTAURANTS Category 3					
Maximum Number of Patrons	Minimum Requirements				
	For Female Patrons		For Male Patrons		
	WCs	Washbasins	WCs	Urinals	Washbasins
1 to 30	N/A allow unisex toilet		1	0	1
31 to 60	1	1	1	0	1
61 to 100	2	1	1	1	2
101 to 150	2	1	1	2	2
151 to 200	2	1	1	3	2
201 to 250	4	2	2	5	3
251 to 300	4	2	2	6	4
301 to 350	4	2	2	7	4
351 to 400	4	2	2	8	4
401 to 450	5	3	3	9	5
451 to 500	5	3	3	10	5

PLACES OF REFRESHMENT							
Maximum Number of Patrons	Minimum Requirements						
	For Female Patrons		For Male Patrons			For Staff	
	WCs	Washbasins	WCs	Urinals	Washbasins	WCs	Washbasins
1 to 15	0	0	0	0	0	1	1
16 to 30	N/A allow unisex		1	0	1	-	-
31 to 60	1	1	1	0	1	-	-
61 and Over	SEE RESTAURANT TABLE						

TOILET REQUIREMENTS FOR LICENSED PREMISES (continued)

Toilet facilities must be:-

- a) Reasonably accessible and not more than one floor distant.
- b) Approached under cover.
- c) Not open directly off a room where food or drink is prepared or consumed.
- d) Arranged to achieve privacy and screened as necessary.
- e) Adequately lighted and ventilated.
- f) Fitted with self closing devices on all approach doors.
- g) Adequately provided with toilet paper, soap and towels.
- h) Provided with facilities for the disposal of sanitary towels.

All wash basins shall be provided with a hot and cold water supply.

Disabled facilities are included when counting toilet numbers for the purposes of the toilet requirement tables.

Health and Social Services Department Environmental Health, Public Health Department

Maison Le Pape, The Parade
St Helier, Jersey, JE2 3PU
Tel: +44 (0)1534 445808
Email: eh@health.gov.je

01 October 2015