

## La Collette Energy from Waste Facility Performance Table

Emissions						
2016	Hydrogen Chloride	Sulphur Dioxide	Nitrous Oxide	Carbon Monoxide	Particulates	Volatile Organic Compound
Month	Expressed as a percentage of the maximum 30 minute limit.					
January	14.12%	11.89%	46.78%	13.41%	1.07%	4.02%
February	13.36%	13.55%	46.51%	15.50%	1.19%	3.08%
March	13.58%	11.86%	46.21%	7.46%	1.52%	2.15%
April	13.19%	15.42%	45.27%	9.53%	2.00%	2.66%
May	11.01%	13.46%	44.99%	15.55%	1.20%	3.44%
June	13.91%	11.59%	46.82%	14.13%	0.77%	0.56%
July	13.58%	10.48%	46.74%	13.79%	0.80%	1.51%
August	13.26%	8.77%	46.34%	8.19%	0.87%	0.68%
September	13.44%	9.49%	49.69%	10.71%	0.87%	0.65%
October	13.86%	10.82%	47.24%	10.34%	0.87%	0.26%
November	14.96%	12.24%	47.28%	16.91%	0.89%	0.04%
December	6.91%	16.19%	43.41%	11.14%	0.89%	0.51%