

La Collette Energy from Waste Facility Performance Table

Emissions						
2015	Hydrogen Chloride	Sulphur Dioxide	Nitrous Oxide	Carbon Monoxide	Particulates	Volatile Organic Compound
Month	Expressed as a percentage of the maximum 30 minute limit.					
January	9.80%	15.95%	50.52%	22.23%	1.31%	8.87%
February	12.25%	14.67%	47.24%	15.49%	1.22%	6.29%
March	5.53%	21.03%	45.27%	10.87%	1.19%	5.48%
April	8.11%	15.67%	43.73%	9.39%	1.14%	4.56%
May	13.94%	7.92%	40.87%	8.19%	1.19%	5.89%
June	13.28%	8.36%	42.64%	10.71%	1.03%	6.88%
July	14.14%	8.83%	40.66%	15.46%	1.14%	5.09%
August	12.58%	7.34%	43.50%	8.28%	2.56%	6.18%
September	13.73%	9.76%	44.15%	10.31%	1.01%	4.91%
October	14.08%	11.53%	46.35%	5.76%	1.00%	3.94%
November	11.69%	11.51%	46.91%	11.18%	1.30%	2.46%
December	14.16%	11.91%	46.47%	12.85%	0.99%	3.32%