

TECHNICAL GUIDANCE DOCUMENT PART 8:
CONSULTATION FINDINGS AND RESPONSE.

Table 1: Responses by type of respondent.

Type of Organisation	Number of responses.
Architect	1
Individual	1
Total	2

Table 2: Consultation findings.

Questions	Yes	No	Don't know
1. Do you think that the proposals in respect of the Changing Places Sanitary Accommodation are reasonable?	2		
2. Do you think that the proposals in respect of Section 6 are reasonable?	2		
3. Do you think that the proposals in respect of Section 8 are reasonable?	2		
4. Do you think that the proposals in respect of Section 9 are reasonable?	2		
5. Do you think that the proposals in respect of Section 10 are reasonable?	2		
6. Do you think that the proposals in respect of Section 11 are reasonable?	2		
7. General suggestions or observations		1	

Response to comments received with the questionnaire returns.

No	Respondent	Comments made.	Departments response	Minister's decision
1.	Architect.	Consideration should be given to merging the CP facility with the standard wheelchair accessible WC.	A Changing Places (CP) facility is a combined toilet, shower and changing room for use by people with complex and multiple disabilities who require the help of up to two assistants. The space needs to be fitted with a fixed tracked hoist system so that assistants can fit the user's slings to the hoist and move the person to the various items in the facility. Due to the nature of its use, the fittings and equipment provided are not designed to meet the needs of independent wheelchair users, as such, combing the two is not considered to be practicable.	No change
1.1		There will arrive a time when the Island is reasonably provided with CP facilities and as such there would be no need for the bye-law requirement.	It is agreed there will arrive a time when the Island is reasonably provided with CP facilities and that when this occurs the need for regulation in this area will diminish.	No change
1.2		The recommendation for locating consumer units within the height range for other switches and sockets may cause issues for electrical	Discussions have been held with representatives of the Jersey Electrical Contractors Association (JECA) regarding the positioning of consumer	No change

		contractors.	units within the height range of 450mm and 1200mm above finished floor level. The outcome of those discussions was that this standard could reasonably be achieved. No formal response to this proposal has been received from the JECA as a result of this consultation.	
1.3		<p>It was suggested that nine CP facilities at the following locations around the Island would be appropriate.</p> <ol style="list-style-type: none"> 1. Airport. 2. Le Braye slipway. St Brelade. 3. St Brelades Bay. 4. St Aubin. 5. Jardins de la Mare. 6. Town Hall, St Helier 7. Elizabeth Terminal. St Helier. 8. Town Park. 9. Gorey Harbour 	It is accepted that the nine locations suggested would provide a good level of coverage, and should CP facilities be provided at those locations this may negate the need for regulation in future.	No change